

Holds a Mechanical Diploma and has about 13 years hands-on experience working as Maintenance Technician at Nubaria Combined Cycle Power Station.

PERSONAL DATA

Nationality : Egyptian
Birth Date : 23/08/1986
Gender : Male
Marital Status : Married
Residence : El-Behira

EDUCATION

: Mechanical Industrial (Grinding – Machining) (3 years)

LANGUAGES

Arabic : Native Language
English : Good

CHRONOLOGICAL EXPERIENCE RECORD

Dates : From 2008 till now
Employer : Middle Delta Electricity Production Company (MDEPC)
Project : Nubaria Combined Cycle Power Station 3x750MW
Job title : Mechanical Maintenance Technician
Job Description :

- Major inspection of unit 5 & 6 Gas turbine at Nubaria (GE 250MW).
- Replacing of the combustion chamber tiles GT 22 & 11 (ceramic and metallic).
- Work as Mechanical Fitter at New Capital Power Plant in:
 - Disassemble the turbine bearing (to modification) Siemens Modules 8000H in the New Capital Power Plant (from 1 Aug. to 30 Oct. 2017).
 - Assemble the turbine bearing Siemens Modules 8000H in the New Capital. Where I have involved for modification on GT bearing seal at GT 31 & 32.
 - Maintenance cooling tower fans in the New Capital Power Plant.
- For Nubaria Power Station in:
 - Follow the operation activity in local for GE gas turbine frame FA9001 (250MW).
 - Assist in CI inspection for GE gas turbine frame FA9001 (250MW)
I worked with supervisor GE company of that inspection in:
 - ❖ Changing cap assembly, combustion linear, transition piece.
 - ❖ Removing flow sleeve, crossfire tubes, fuel nozzle casing.

- ❖ Make clearance checkup for VIGV by taking backlash, inner bearing clearance & gap between VIGV and bearing casing (body).
- Participate in warranty inspection for GE gas turbine frame FA9001 (250MW) I worked with GE's technical advisor company of that inspection.
- Participate in Major inspection for GE gas turbine frame FA9001 (250MW) I worked with GE's technical advisor company of that inspection.
- Assist in major inspection (LTE) for 4 units SIEMENS gas turbine.
- Assist in minor inspection for 4 unit Siemens gas turbine V94.3A (250MW) I worked with Siemens group of that inspection in:
 - ❖ Chemical cleaning for burners.
 - ❖ Changing of ceramic tiles of combustion chamber.
 - ❖ Visual inspection of turbine & compressor blades.
- Assist in hot gas path inspection for 4 unit Siemens gas turbine V94.3A (250MW) I worked with Siemens group of that inspection in:
 - ❖ Removing the outer casing in the turbine section.
 - ❖ Lifting off upper sections of the turbine stationary blades carrier.
 - ❖ Rolling out the lower section of the turbine stationary blades carrier.
 - ❖ Removing blades / vans for refurbishment / replacement.
 - ❖ Chemical cleaning for burners.
 - ❖ Changing of ceramic tiles of combustion chamber.
 - ❖ Check clearance for 1st stage compressor & 4th stage turbine blades.
 - ❖ Removing and inspection fuel oil and fuel gas stop and control valves and make passing test for all valves.
- Assist in major inspection for 4 units Siemens gas turbine V94.3A (250MW) I worked with Siemens group of that inspection in:
 - ❖ Chemical cleaning for burners.
 - ❖ Changing of ceramic tiles & damage ceramic heat shield of combustion chamber.
 - ❖ Visual inspection of compressor blades.
 - ❖ Check the axial & radial clearance for blades.
 - ❖ Removing the outer casing in the turbine section (Casing 3).
 - ❖ Removing the casing of combustion chamber (Casing 2).
 - ❖ Removing the compressor casings (casing 1, 2 comp).
 - ❖ Lifting off upper sections of the turbine stationary blades carrier.
 - ❖ Lifting off lower section of the turbine stationary blades carrier.
 - ❖ Removing old blades/vans for refurbishment /replacement for all turbine & compressor.
 - ❖ Lifting the rotor from horizontal position to vertical one.
 - ❖ Des-tacking the rotor.
 - ❖ Make NDT for all critical places (as slots of the blades of the compressor & turbine disks).
 - ❖ Make alignment between the gas turbine & and generator shaft.
 - ❖ Make oil flushing.
 - ❖ Removing and inspection fuel oil and fuel gas stop and control valves and make passing test for all valves.
 - ❖ Removing fuel oil pumps and makes inspection of internal parts and reassembly again and make alignment for the pump.
 - ❖ Removing hydraulic oil pump and make inspection of internal

- parts and reassembly again.
- Assist in minor inspection for Mitsubishi steam turbine (250MW)
I worked with supervisor Mitsubishi Company of that inspection in:
 - ❖ Make oil flushing as:
 - Cleaning of oil storage tank.
 - Oil transfer to oil storage tank.
 - Cleaning of main oil tank.
 - Oil transfer to main oil tank.
 - ❖ Cleaning and inspection of oil purifier.
 - ❖ Cleaning and inspection of oil cooler.
 - ❖ Inspection and cleaning of water chamber for condenser.
 - ❖ Inspection and cleaning of hot well for condenser alignment check for pumps (vacuum pump, oil pump etc.).
- Assist in Major inspection for Mitsubishi steam turbine (250MW)
I worked with supervisor Mitsubishi Company of that inspection in:
 - ❖ Removing upper casing for HP - IP turbines.
 - ❖ Removing upper casing for LP turbine.
 - ❖ Removing the stationary blades diaphragms.
 - ❖ Lifting off the rotor.
 - ❖ Inspection for internal parts.
 - ❖ Check the axial & radial clearance for blades.
 - ❖ Make alignment for HP-IP & LP and generator shaft.
 - ❖ Removing the control valves & stop valves and check for internal parts.
 - ❖ Make oil flushing.
 - ❖ Cleaning of oil storage tank.
 - ❖ Oil transfer to oil storage tank.
 - ❖ Cleaning of main oil tank.
 - ❖ Oil transfer to main oil tank.
 - ❖ Cleaning and inspection of oil purifier.
 - ❖ Cleaning and inspection of oil cooler.
 - ❖ Inspection and cleaning of water chamber for condenser.
- Inspection of Generator for Mitsubishi steam turbine 250MW.

- Further experiences :**
- Doing the maintenance schedules (daily - weekly - monthly - ...etc.).
 - Maintenance of the Atlas Copco compressors of the air intake.
 - Also we did together the cold commissioning of the fuel oil for four units of Nubaria Power Station.
 - Also we did together the hot commissioning of the fuel oil for four units of Nubaria Power Station.
 - Good knowledge about the spare parts of V94.3A (2) gas turbines.
 - Good knowledge about the special tools of the V94.3A (2) (SGT-4000F) gas turbines.
 - Maintenance of blow off valves.
 - Maintenance of Boge compressors.
 - Maintenance of trash racks.
 - Maintenance of traveling screens.